

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

## Certificate of constancy of performance

0761 – CPR – 0838

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

**Single leaf and double sliding doors with or without passdoor  
with fire resistance and/or smoke control characteristics  
with the trade name “NovoSlide Industry“**

**classifications according to EN 13501-2:2016:**

**El<sub>2</sub> 30 – S<sub>a</sub> C3 / El<sub>2</sub> 60 – S<sub>a</sub> C3 / El<sub>2</sub> 90 – S<sub>a</sub> C3 / El<sub>2</sub> 120 – S<sub>a</sub> C3 /  
El<sub>2</sub> 30 – S<sub>200</sub> C3 / El<sub>2</sub> 60 – S<sub>200</sub> C3 / El<sub>2</sub> 90 – S<sub>200</sub> C3 / El<sub>2</sub> 120 – S<sub>200</sub> C3 /  
E 120 – C3, / E 120 – S<sub>a</sub> C3 / E 120 – S<sub>200</sub> C3 /  
EW 120 – C3 / EW 120 – S<sub>a</sub> C3 / EW 120 – S<sub>200</sub> C3**

produced by or for

**Novoferm GmbH  
Schützensteiner Straße 26  
46419 Isselburg-Werth  
Germany**

in the manufacturing plants

**Brackenheim or Isselburg-Werth (both in Germany).**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 16034:2014 in connection with EN 13241:2003+A2:2016**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate has an annex with one page. It was first issued on 2020-01-21 and will remain valid until 2026-03-15, as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 2021-03-16

Z-3/1443/17

.....  
Dr.-Ing. W. Hinrichs  
Head of certification



Combinations of performance parameters and classes based on EN 13501-2:2016 (Classification report No.: K-5036-DMT-DO of DMT GmbH & Co. KG, Dortmund, Germany, of 2021-02-25):

<b>E-C</b>	E 30-C3	E 60-C3	E 90-C3	E 120-C3
<b>EW-C</b>	EW 30-C3	EW 60-C3	EW 90-C3	EW 120-C3
<b>E-S<sub>a</sub>-C</b>	E 30-S <sub>a</sub> -C3	E 60-S <sub>a</sub> -C3	E 90-S <sub>a</sub> -C3	E 120-S <sub>a</sub> -C3
<b>EW-S<sub>a</sub>-C</b>	EW 30-S <sub>a</sub> -C3	EW 60-S <sub>a</sub> -C3	EW 90-S <sub>a</sub> -C3	EW 120-S <sub>a</sub> -C3
<b>E-S<sub>200</sub>-C</b>	E 30-S <sub>200</sub> -C3	E 60-S <sub>200</sub> -C3	E 90-S <sub>200</sub> -C3	E 120-S <sub>200</sub> -C3
<b>EW-S<sub>200</sub>-C</b>	EW 30-S <sub>200</sub> -C3	EW 60-S <sub>200</sub> -C3	EW 90-S <sub>200</sub> -C3	EW 120-S <sub>200</sub> -C3
<b>El<sub>2</sub>-C</b>	El <sub>2</sub> 30-C3	El <sub>2</sub> 60-C3	El <sub>2</sub> 90-C3	El <sub>2</sub> 120-C3
<b>El<sub>2</sub>-S<sub>a</sub>-C</b>	El <sub>2</sub> 30-S <sub>a</sub> -C3	El <sub>2</sub> 60-S <sub>a</sub> -C3	El <sub>2</sub> 90-S <sub>a</sub> -C3	El <sub>2</sub> 120-S <sub>a</sub> -C3
<b>El<sub>2</sub>-S<sub>200</sub>-C</b>	El <sub>2</sub> 30-S <sub>200</sub> -C3	El <sub>2</sub> 60-S <sub>200</sub> -C3	El <sub>2</sub> 90-S <sub>200</sub> -C3	El <sub>2</sub> 120-S <sub>200</sub> -C3

----- End of the certificate of constancy of performance -----